

浙江三美化工股份有限公司

ZHEJIANG SANMEI CHEMICAL IND. CO., LTD.

浙江省武义县青年路胡处

HUCHU, WUYI COUNTY, ZHEJIANG PROVINCE, CHINA

Tel: 0086-579-87649587 Fax: 0086-579-87645878

CERTIFICATE OF ANALYSIS

Sample name: R410A

Invoice NO: LN2208B

Sample source: CYLINDER

Sampling time: MAY 21, 2023

Product standard: HG/T 5162-2017

Density items	Standard demands	Results
Appearance	Colorless and no smelling	
Purity%	≥ 99.9	99.99
Moisture% $\leq$	≤ 0.0010	0.00074
HFC-32, %	49.5 ± 1	49.1
HFC-125, %	50.5 ± 1	50.9
Evaporation residue%	≤ 0.01	0.0008
Acidity (as HCL) %	≤ 0.0001	< 0.0001
Chloride (content of CL-) %	PASS	PASS
Non Condensable Gas %	≤ 1.5	0.28
Product amount: 17.76MT	Final conclusion: Conformity	
Tester: TANG XINGDONG Checker: GAO RONGFU Auditor: TANG SHAOXIONG	浙江三美化工股份有限公司 ZHEJIANG SANMEI CHEMICAL IND. CO., LTD 胡博翔	